

Roscommon County Road Commission

Scott Eckstorm, Commissioner
James Porath, Commissioner
Clint Stauffer, Commissioner
Brian Vaughn, Commissioner
Justin Wykoff, Commissioner

820 E. West Branch Road
Prudenville, MI 48651

Roger Saxton, Manager
Phone:(989)366-0333
Fax:(989)366-0299
Website: www.roscommoncrc.com
E-mail: rrcr@roscommoncrc.com

**Old US 27 (South Harrison Rd)
Job Number: 220255**

Q&A

Issued 01-16-2025

1. Are contractors required to be MDOT prequalified?
 - a. No
2. Is there federal funding on this project?
 - a. No, this project only has state funding.
3. The concrete cross culvert calls for concrete end sections. Will metal end sections with inserts be ok? If not, will we need to pour footings for the concrete end sections?
 - a. Addendum A will be issued to delete the concrete end sections and add in metal end sections that can be inserted into the concrete pipe.
4. Will density testing be the contractor's responsibility or will RCRC provide testing services if needed?
 - a. RCRC will provide any required density testing for this project..