

Roscommon County Road Commission(RCRC)

Cured-in-Place Pipe Liner #2

Questions and Answers

1. Is UV CIPP an approved equivalent?
 - **Yes**
2. Are MDOT permits required for traffic control?
 - **No**
3. Are there videos available?
 - **Videos have been made available at the following link:**
https://roscommonroad-my.sharepoint.com/:f/g/person/belangern_roscommoncrc_com/Ehhw_fRaS8JEucGI_Sam9npwB-w2Wyo6MQwlzHqK4-SjH2Q?e=OqbXdg
4. Is steam cure allowed?
 - **Yes**
5. What is the existing pipe material?
 - **Concrete and metal, can also see videos.**
6. Are manhole depths available for design calculations?
 - **Manhole depths are not available.**
7. Can the deadline for completion be extended.
 - **No**
8. Is a bid bond required?
 - **No**
9. There is a duplicate for line 72 to 71, can you clarify?
 - **Delete line 72 to 71 with the associated 39' of 12-inch CIPP. This deletes 39 feet of 12 inch liner from the bid. New bid docs will not be issued please line out the total and write in the correct number.**
10. Can you clarify line 65 to 64_1?
 - **It was found that this is a typo. This line should be 65 to 64 with an associated length of 77 feet of 12 inch. This adds an additional 23 feet of liner to the 12 inch line. New bid docs will not be issued please line out the total and write in the correct number.**